

<b>School Ventilation as of 20 November 2020</b>					
<b>Ward</b>	<b>School Name</b>	<b>School Ventilation - see Notes below</b>	<b>LC</b>	<b>LN</b>	<b>HEPA Filters Provided</b>
1	30 Barrhead Cres Learning Ctr/CSS LC1	partial mechanical	5	31	Yes
1	Albion Heights Junior MS	all mechanical	1	2	No
1	Beaumonde Heights Junior MS	partial mechanical	1	2	Yes
1	Braeburn Junior School	partial mechanical	1	2	Yes
1	Claireville Junior School	partial mechanical	1	1	Yes
1	Elmbank JR-MS Academy	partial mechanical	1	2	Yes
1	Elmlea Junior School	partial mechanical	1	1	No
1	Greenholme JR-MS	partial mechanical	1	2	Yes
1	Highfield Junior School	partial mechanical	1	1	Yes
1	Humberwood Downs Jr. M. Acad.	all mechanical	1	2	No
1	John D. Parker Junior School	all mechanical	1	1	No
1	Kingsview Village JS	partial mechanical	1	2	Yes
1	Linc Albion Mall	all mechanical			No
1	Melody Village Junior School	all mechanical	1	2	No
1	North Albion CI	all mechanical	1	1	No
1	North Kipling Junior MS	all mechanical	1	1	No
1	Parkfield Junior School	partial mechanical	1	2	Yes
1	Rivercrest Junior School	partial mechanical	1	2	Yes
1	School of Experiential Ed.	partial mechanical	5	30	Yes
1	Smithfield Middle School	all mechanical	1	1	No
1	The Elms Junior Middle School	partial mechanical	1	2	Yes
1	Thistletown CI	partial mechanical	1	2	Yes
1	West Humber CI	all mechanical	1	2	No
1	West Humber Junior MS	partial Mechanical	1	2	Yes
2	Bloordale MS	all mechanical	1	1	No
2	Bloorlea Middle School	partial mechanical	1	1	Yes
2	Briarcrest Junior School	all mechanical	1	1	No
2	Broadacres Junior School	partial mechanical	1	1	Yes
2	Burnhamthorpe CI	partial mechanical	1	1	Yes
2	Central Etobicoke High School*	all mechanical	1	3	No
2	Dixon Grove Junior MS	partial mechanical	1	3	Yes
2	Eatonville Junior School	all mechanical	1	1	No
2	Etobicoke Collegiate Institute	all mechanical	1	2	No
2	Hilltop Middle School	partial mechanical	1	3	Yes
2	Hollycrest Middle School	all mechanical	1	1	No
2	Humber Valley Village JR MS	all mechanical	1	2	No
2	John G. Althouse MS	partial mechanical	1	2	Yes
2	Kipling Collegiate Institute	all mechanical	1	3	No
2	Martingrove CI	all mechanical	1	2	No
2	Mill Valley Junior School	partial mechanical	1	1	Yes
2	Millwood Junior School	partial mechanical	1	1	Yes
2	Princess Margaret Junior PS	partial mechanical	1	2	Yes
2	Richview Collegiate Institute	all mechanical	1	2	No

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
2	Rosethorn Junior School	partial mechanical	1	2	Yes
2	Seneca School *	partial mechanical	1	1	Yes
2	Silverthorn CI	all mechanical	1	1	No
2	St. George's Junior School	no mechanical	1	2	Yes
2	Valleyfield Junior School	partial mechanical	1	3	Yes
2	Wedgewood Junior School	partial mechanical	1	1	Yes
2	Wellesworth Junior School	all mechanical	1	1	No
2	West Glen Junior School	partial mechanical	1	1	Yes
2	Westmount Junior School	partial mechanical	1	3	Yes
2	Westway Junior School	no mechanical	1	3	Yes
3	Castlebar Junior School	all mechanical	4	20	No
3	David Hornell Junior School	no mechanical	4	19	Yes
3	Étienne Brûlé Junior School	partial mechanical	4	20	Yes
3	Etobicoke School of the Arts	all mechanical	4	20	No
3	Etobicoke Year Round Alternative Centre	no mechanical	5	30	Yes
3	George R. Gauld Junior School	partial mechanical	4	19	Yes
3	Islington Junior Middle School	all mechanical	4	19	No
3	James S Bell JMS Sports & Wellness Acad.	all mechanical	4	19	No
3	John English JMS	partial mechanical	4	19	Yes
3	Karen Kain School of the Arts	no mechanical	4	20	Yes
3	Lakeshore Collegiate Institute	partial mechanical	4	19	Yes
3	Lambton Kingsway JR MS	all mechanical	4	19	No
3	Lanor Junior Middle School	partial mechanical	4	19	Yes
3	Norseman Junior Middle School	all mechanical	4	20	No
3	Park Lawn Junior MS	all mechanical	4	20	No
3	Second Street Junior MS	partial mechanical	4	19	Yes
3	Seventh Street Junior School	all mechanical	4	19	No
3	Sir Adam Beck Junior School	all mechanical	4	19	No
3	Sunnylea Junior School	partial mechanical	4	20	Yes
3	Twentieth Street Junior School	all mechanical	4	19	No
4	Blacksmith PS	all mechanical	2	7	No
4	Brookview MS	all mechanical	2	7	No
4	C.W. Jefferys CI	all mechanical	2	7	No
4	Chalkfarm PS	all mechanical	2	7	No
4	Daystrom PS	partial mechanical	2	11	Yes
4	Derrydown PS	partial mechanical	2	7	Yes
4	Driftwood PS	all mechanical	2	7	No
4	Elia Middle School	all mechanical	2	7	No
4	Emery Collegiate Institute	all mechanical	2	11	No
4	Firgrove PS	all mechanical	2	7	No
4	Gosford PS	partial mechanical	2	7	Yes
4	Gracedale PS	partial mechanical	2	11	Yes
4	Gulfstream PS	partial mechanical	2	11	Yes
4	Humber Summit MS	partial mechanical	2	11	Yes

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
4	Lamberton PS	all mechanical	2	7	No
4	Oakdale Park MS	all mechanical	2	7	No
4	Shoreham Public Sports & Wellness Acad.	all mechanical	2	7	No
4	Stanley PS	partial mechanical	2	7	Yes
4	Topcliff PS	partial mechanical	2	7	Yes
4	Westview Centennial SS	all mechanical	2	11	No
4	Yorkwoods PS	all mechanical	2	7	No
5	Ancaster Public School	partial mechanical	2	12	Yes
5	Beverley Heights Middle School	partial mechanical	2	8	Yes
5	Blaydon PS	partial mechanical	2	12	Yes
5	Calico Public School*	partial mechanical	2	8	Yes
5	Charles H Best MS	all mechanical	2	8	No
5	Dellcrest Public School	all mechanical	0	99	No
5	Downsview Public School	partial mechanical	2	12	Yes
5	Downsview Secondary School	partial mechanical	2	12	Yes
5	Dublin Heights E & MS	partial mechanical	2	12	Yes
5	Faywood Arts Based Curriculum S	partial mechanical	2	12	Yes
5	Highview Public School	partial mechanical	2	12	Yes
5	Northview Heights SS	all mechanical	2	8	No
5	Pierre Laporte Middle School	all mechanical	2	12	No
5	Rockford Public School	partial mechanical	2	8	Yes
5	Sheppard PS / Africentric Alt School	partial mechanical	2	11	Yes
5	Stilecroft PS	partial mechanical	2	11	Yes
5	Summit Heights PS	no mechanical	2	12	Yes
5	Tumpane Public School	partial mechanical	2	8	Yes
5	William Lyon Mackenzie CI	all mechanical	2	12	No
5	Wilmington Elementary School	partial mechanical	2	8	Yes
6	Amesbury Middle School	all mechanical	1	3	No
6	Bala Avenue Community School	all mechanical	1	3	No
6	Brookhaven Public School	all mechanical	1	3	No
6	C.R. Marchant Middle MS	partial mechanical	1	3	Yes
6	Charles E Webster Public School	partial mechanical	1	4	Yes
6	Cordella Junior PS	all mechanical	1	4	No
6	Dennis Avenue Community School	partial mechanical	1	4	Yes
6	Frank Oke Secondary School	partial mechanical	1	4	Yes
6	George Anderson Public School	no mechanical	1	3	Yes
6	George Harvey CI	partial mechanical	1	3	Yes
6	George Syme Community School	all mechanical	1	4	No
6	Gracefield Public School	no mechanical	1	3	Yes
6	H.J. Alexander Comm. School	all mechanical	1	1	No
6	Harwood Jr. PS	partial mechanical	1	4	Yes
6	Keelesdale Jr. PS	partial mechanical	1	4	Yes
6	Lambton Park Community School	partial mechanical	1	4	Yes
6	Maple Leaf Public School	partial mechanical	1	3	Yes

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
6	Pelmo Park Public School	partial mechanical	1	3	Yes
6	Portage Trail CJS/CMS	all mechanical	1	99	No
6	Rockcliffe Middle School	partial mechanical	1	4	Yes
6	Roselands Jr. PS	all mechanical	1	4	No
6	Silverthorn CS	all mechanical	1	4	No
6	Weston Collegiate Institute	all mechanical	1	3	No
6	Weston Memorial Jr PS	partial mechanical	1	3	Yes
6	York Humber High School*	all mechanical	1	3	No
6	York Memorial CI	all mechanical	1	3	No
7	Annette Street Jr. & Sr. PS	all mechanical	4	20	No
7	Fern Avenue Jr. & Sr. PS	all mechanical	4	19	No
7	Garden Avenue Junior PS	all mechanical	4	19	No
7	Howard Jr. PS	all mechanical	4	19	No
7	Humbercrest Public School	partial mechanical	4	20	Yes
7	Humberside CI	all mechanical	4	20	No
7	Indian Road Crescent Jr. PS	all mechanical	4	20	No
7	Keele Street PS	all mechanical	4	19	No
7	King George Jr. PS	all mechanical	4	20	No
7	Lucy McCormick School Senior*	all mechanical	4	20	No
7	Parkdale Collegiate Institute	all mechanical	4	19	No
7	Parkdale Jr. & Sr. PS	all mechanical	4	19	No
7	Queen Victoria Junior PS	all mechanical	4	19	No
7	Runnymede Collegiate Institute	all mechanical	4	20	No
7	Runnymede Jr. & Sr. PS	all mechanical	4	20	No
7	Swansea Jr. & Sr. PS	all mechanical	4	20	No
7	Warren Park Jr. PS	partial mechanical	4	19	Yes
7	Western Tech. & Comm. School	all mechanical	4	19	No
8	Allenby Junior Public School	partial mechanical	1	6	Yes
8	Armour Heights Public School	no mechanical	1	6	Yes
8	Baycrest Public School	no mechanical	1	4	Yes
8	Brown Jr PS & City Community Centre	all mechanical	1	5	No
8	Cedarvale Community School	partial mechanical	1	6	Yes
8	Cottingham Jr. Public School	partial mechanical	1	5	Yes
8	Davisville Jr PS/Spectrum Alt Sr School	partial mechanical	1	4	Yes
8	Deer Park Jr. & Sr. PS	partial mechanical	1	5	Yes
8	Eglinton Jr PS	all mechanical	1	5	No
8	Fairbank Public School	all mechanical	1	4	No
8	Flemington Public School	partial mechanical	1	4	Yes
8	Forest Hill CI	all mechanical	1	6	No
8	Forest Hill Jr. & Sr. PS	no mechanical	1	6	Yes
8	Glen Park Public School	all mechanical	1	4	No
8	Glenview Sr. PS	all mechanical	1	5	No
8	Hillcrest Community School	all mechanical	1	5	No
8	Humewood Community School	all mechanical	1	5	No

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
8	J.R. Wilcox Community School	partial mechanical	1	1	Yes
8	John Polanyi CI / Bathurst Heights LC	partial mechanical	1	4	Yes
8	John Ross Robertson Jr. PS	all mechanical	1	5	No
8	John Wanless Junior PS	partial mechanical	1	6	Yes
8	Joyce Public School	partial mechanical	1	4	Yes
8	Lawrence Heights Middle School	partial mechanical	1	4	Yes
8	Lawrence Park CI	partial mechanical	1	5	Yes
8	Ledbury Park E & MS	partial mechanical	1	4	Yes
8	McMurrich Junior Public School	partial mechanical	1	5	Yes
8	North Preparatory Junior PS	partial mechanical	1	6	Yes
8	North Toronto CI	all mechanical	1	6	No
8	Oriole Park Junior PS	partial mechanical	1	6	Yes
8	West Preparatory Junior PS	all mechanical	1	6	No
8	Winona Drive Senior PS	all mechanical	1	5	No
8	Yorkdale Secondary School	partial mechanical	1	4	Yes
9	Alexander Muir/Gladstone / The Grove CS	all mechanical	4	21	No
9	Alpha Alternative JS/Oasis Altern. SS	no mechanical	4	22	Yes
9	Bloor Collegiate Institute	all mechanical	4	21	No
9	Brock Public School	partial mechanical	4	21	Yes
9	Carleton Village J&S Sports & Wellness	all mechanical	4	20	No
9	Charles G Fraser Jr PS (West End Creche)	partial mechanical	4	21	Yes
9	Contact Alternative School	all mechanical	5	30	No
9	Dewson Street Junior PS	all mechanical	4	21	No
9	Dovercourt Public School	partial mechanical	4	21	Yes
9	Downtown Alternative Sch. Jr.	all mechanical	4	22	No
9	F.H. Miller Jr. PS	partial mechanical	4	4	Yes
9	Fairbank Memorial Comm. School	partial mechanical	4	20	Yes
9	General Mercer Jr. PS	partial mechanical	4	20	Yes
9	Givins/Shaw Jr. & Sr. PS	all mechanical	4	21	No
9	Island PS/Nat. Science School	all mechanical	4	22	No
9	Jean Lumb PS	all mechanical	4	22	No
9	Niagara Street Junior PS	partial mechanical	4	21	Yes
9	Oakwood Collegiate Institute	all mechanical	4	20	No
9	Ogden Junior Public School	all mechanical	4	22	No
9	Ossington/Old Orchard Jr. PS	all mechanical	4	21	No
9	Pauline Junior Public School	all mechanical	4	21	No
9	Perth Avenue Junior PS	all mechanical	4	20	No
9	Rawlinson Community School	partial mechanical	4	20	Yes
9	Regal Road Junior PS	partial mechanical	4	20	Yes
9	Ryerson Comm. Sch. Jr. & Sr.	all mechanical	4	22	No
9	Shirley Street Jr. PS	all mechanical	4	21	No
9	The Waterfront School	all mechanical	4	22	No
10	Beverley R PS*	partial mechanical	4	21	Yes
10	Central Technical School	all mechanical	4	21	No

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
10	Central Toronto Academy	all mechanical	4	21	No
10	Church Street Jr PS/Native Learning Ctr	all mechanical	4	21	No
10	Clinton Street Junior PS	all mechanical	4	21	No
10	Essex Jr. & Sr. PS	all mechanical	4	21	No
10	Harbord Collegiate Institute	all mechanical	4	21	No
10	Heydon Park SS (New)	all mechanical	4	22	No
10	Huron Street Junior PS	partial mechanical	4	21	Yes
10	Inglenook Community HS	partial mechanical	5	30	Yes
10	Jarvis Collegiate Institute	all mechanical	4	22	No
10	Jesse Ketchum Jr. & Sr. PS	partial mechanical	4	21	Yes
10	Kensington Community Sch. Jr.	all mechanical	4	21	No
10	King Edward Jr. & Sr. PS	all mechanical	4	22	No
10	Lord Dufferin Jr. & Sr. PS	all mechanical	4	22	No
10	Lord Lansdowne Junior Public School	all mechanical	4	22	No
10	Market Lane Jr. & Sr. PS	all mechanical	4	22	No
10	Montrose Junior Public School	all mechanical	4	21	No
10	Nelson Mandela Park P.S	all mechanical	4	22	No
10	Orde Street Public School	partial mechanical	4	22	Yes
10	Palmerston Junior PS	all mechanical	4	21	No
10	Rose Avenue Jr. Public School	all mechanical	4	22	No
10	Rosedale Hts Sch of the Arts	all mechanical	4	22	No
10	Rosedale Jr. Public School	all mechanical	4	22	No
10	Sprucecourt Public School	all mechanical	4	22	No
10	West End Alternative/Bickford	all mechanical	5	30	No
10	Whitney Junior Public School	all mechanical	4	22	No
10	Winchester Jr. & Sr. PS	all mechanical	4	22	No
11	Bedford Park Public School	no mechanical	1	6	Yes
11	Bennington Heights ES	partial mechanical	1	5	Yes
11	Bessborough Drive ES	partial mechanical	1	5	Yes
11	Blythwood Junior Public School	partial mechanical	1	6	Yes
11	Denlow Public School	all mechanical	1	6	No
11	Dunlace Public School	partial mechanical	1	6	Yes
11	Fraser Mustard Early Learning Academy	all mechanical	1	5	No
11	Harrison Public School	no mechanical	1	6	Yes
11	Hodgson Middle School	all mechanical	1	5	No
11	John Fisher Junior PS	partial mechanical	1	6	Yes
11	Leaside High School	all mechanical	1	5	No
11	Marc Garneau CI	all mechanical	1	5	No
11	Maurice Cody Jr. Public School	partial mechanical	1	5	Yes
11	Northern Secondary School	all mechanical	1	6	No
11	Northlea E. & M.S.	all mechanical	1	5	No
11	Owen Public School	all mechanical	1	6	No
11	Park Lane Public School*	all mechanical	1	6	No
11	Rippleton Public School	partial mechanical	1	6	Yes

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
11	Rolph Road ES	no mechanical	1	5	Yes
11	St. Andrew's Middle School	partial mechanical	1	6	Yes
11	Sunny View Jr. & Sr. PS*	all mechanical	1	6	No
11	Thornccliffe Park ES	partial mechanical	1	5	Yes
11	Windfields Junior High School/MS	all mechanical	1	6	No
11	York Mills CI	all mechanical	1	6	No
12	Avondale PS/Avondale Elem Alt School	all mechanical	2	12	No
12	Avondale Secondary Alternative School	no mechanical	5	30	Yes
12	Cameron Public School	partial mechanical	2	8	Yes
12	Churchill Public School	all mechanical	2	8	No
12	Claude Watson School for Arts	all mechanical	2	12	No
12	Cummer Valley Middle School	all mechanical	2	12	No
12	Drewry SS*	partial mechanical	2	12	Yes
12	Earl Haig Secondary School	partial mechanical	2	12	Yes
12	Finch Public School	partial mechanical	2	12	Yes
12	Fisherville Sr PS//NW Year Round Alt Ctr	partial mechanical	2	12	Yes
12	Forest Valley Outdoor Ed. Ctr	partial mechanical			Yes
12	Hollywood Public School	no mechanical	2	12	Yes
12	Kenton Public School	partial mechanical			Yes
12	Lillian Public School	no mechanical	2	12	Yes
12	McKee Public School	all mechanical	2	12	No
12	Newtonbrook Secondary School	all mechanical	2	8	No
12	Pleasant Public School	no mechanical	2	12	Yes
12	R.J. Lang Elementary E. & M.S.	all mechanical	2	12	No
12	Willowdale Middle School	no mechanical	2	8	Yes
12	Yorkview Public School	partial mechanical	2	12	Yes
13	A.Y. Jackson Secondary School	all mechanical	2	8	No
13	Arbor Glen Public School	all mechanical	2	8	No
13	Bayview MS	partial mechanical	2	8	Yes
13	Brian Public School	partial mechanical	2	9	Yes
13	Cherokee Public School	all mechanical	2	9	No
13	Cliffwood Public School	all mechanical	2	8	No
13	Cresthaven Public School	all mechanical	2	8	No
13	Crestview Public School	all mechanical	2	11	No
13	Dallington Public School	all mechanical	2	11	No
13	Don Valley Middle School	all mechanical	2	11	No
13	Elkhorn Public School	partial mechanical	2	8	Yes
13	Ernest Public School	all mechanical	2	9	No
13	Forest Manor Public School	all mechanical	2	11	No
13	Georges Vanier SS	all mechanical	5	99	No
13	Highland Middle School	all mechanical	2	8	No
13	Hillmount Public School	all mechanical	2	8	No
13	Kingslake Public School	all mechanical	2	11	No
13	Lescon Public School	all mechanical	2	11	No

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
13	Lester B. Pearson PS	partial mechanical	2	8	Yes
13	Muirhead Public School	all mechanical	2	9	No
13	Pineway Public School	all mechanical	2	8	No
13	Pleasant View Middle School	all mechanical	2	9	No
13	Seneca Hill Public School	all mechanical	2	11	No
13	Shaughnessy Public School	all mechanical	2	9	No
13	Steelesview Public School	all mechanical	2	8	No
13	Woodbine Middle School/NEYRAC	partial mechanical	2	11	Yes
13	Zion Heights Middle School	all mechanical	2	8	No
14	Broadlands Public School	all mechanical	2	9	No
14	Cassandra Public School	partial mechanical	2	10	Yes
14	Don Mills Collegiate Institute	all mechanical	2	9	No
14	Don Mills Middle School	all mechanical	2	9	No
14	Donview Middle Health & Wellness Acad.	all mechanical	2	9	No
14	Fenside Public School	all mechanical	2	11	No
14	Gateway Public School	all mechanical	2	10	No
14	George S. Henry Academy	all mechanical	2	9	No
14	Greenland Public School	partial mechanical	2	9	Yes
14	Grenoble Public School	partial mechanical	2	10	Yes
14	Milne Valley Middle School	all mechanical	2	10	No
14	Norman Ingram Public School	partial mechanical	2	9	Yes
14	Overland PS	partial mechanical			Yes
14	Ranchdale Public School	partial mechanical	2	10	Yes
14	Rene Gordon Health & Wellness Academy	all mechanical	2	9	No
14	Roywood Public School	partial mechanical	2	11	Yes
14	S H Armstrong Recreation Centre	all mechanical			No
14	Sloane Public School	partial mechanical	2	9	Yes
14	Three Valleys Public School	partial mechanical	2	9	Yes
14	Valley Park Middle School	all mechanical	2	10	No
14	Victoria Park Collegiate Institute	partial mechanical	2	10	Yes
14	Victoria Village Public School	partial mechanical	2	9	Yes
15	Blake Street Junior PS	all mechanical	4	23	No
15	Bruce Public School	all mechanical	4	23	No
15	Chester Elementary School	partial mechanical	4	24	Yes
15	City Adult Learning Centre	partial mechanical	4	22	Yes
15	Cosburn Middle School	all mechanical	4	24	No
15	Danforth CTI/Greenwood SS	all mechanical	4	24	No
15	Diefenbaker Elementary School	all mechanical	4	24	No
15	Duke Of Connaught Jr & Sr PS	all mechanical	4	23	No
15	Dundas Jr PS	all mechanical	4	22	No
15	Earl Grey Senior Public School	all mechanical	4	23	No
15	Eastdale Collegiate Institute	all mechanical	4	22	No
15	Eastern Ave Centre	all mechanical	4	99	No
15	Frankland Community Junior PS	all mechanical	4	23	No



Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
15	Jackman Avenue Junior PS	all mechanical	4	24	No
15	Leslieville Junior PS	all mechanical	4	23	No
15	Monarch Park CI/SOLE	all mechanical	4	23	No
15	Morse Junior Public School	all mechanical	4	23	No
15	Pape Avenue Junior Public Scho	all mechanical	4	23	No
15	Queen Alexandra Senior PS	all mechanical	4	22	No
15	R H McGregor ES	all mechanical	4	24	No
15	Riverdale Collegiate Institute	all mechanical	4	23	No
15	Roden PS / Equinox Holistic Alt School	all mechanical	4	23	No
15	Wandering Spirit/Subway Academy 1	all mechanical	5	32	No
15	Westwood Middle School	all mechanical	4	24	No
15	Wilkinson Junior PS	all mechanical	4	24	No
15	William Burgess ES	partial mechanical	4	24	Yes
15	William J. Mccordic School*	all mechanical	4	24	No
15	Withrow Avenue Jr. PS	all mechanical	4	23	No
16	Adam Beck Junior Public School	all mechanical	4	23	No
16	Balmy Beach Community Sch. Jr.	all mechanical	4	23	No
16	Bowmore Road Jr & Sr PS	all mechanical	4	23	No
16	Crescent Town ES	all mechanical	4	24	No
16	D.A. Morrison MS	all mechanical	4	24	No
16	Earl Beatty Jr. & Sr. PS	partial mechanical	4	24	Yes
16	Earl Haig Public School	partial mechanical	4	23	Yes
16	East York Alternative SS	all mechanical	5	30	No
16	East York Collegiate Institute	all mechanical	4	24	No
16	George Webster ES	all mechanical	4	24	No
16	Gledhill Jr. Public School	all mechanical	4	24	No
16	Glen Ames Sr PS	all mechanical	4	23	No
16	Gordon A. Brown Middle School	all mechanical	4	24	No
16	Kew Beach Junior Public School	all mechanical	4	23	No
16	Kimberley Junior Public School	all mechanical	4	23	No
16	Malvern Collegiate Institute	all mechanical	4	23	No
16	Norway Junior Public School	all mechanical	4	23	No
16	Oak Park	all mechanical			No
16	O'Connor Public School	all mechanical	4	24	No
16	Parkside Elementary School	all mechanical	4	24	No
16	Presteign Heights ES	partial mechanical	4	24	Yes
16	Secord Elementary School	all mechanical	4	24	No
16	Selwyn ES	partial mechanical	4	24	Yes
16	Victoria Park Elementary S.	partial mechanical	4	24	Yes
16	Williamson Road Junior PS	all mechanical	4	23	No
17	Buchanan Public School	partial mechanical	3	18	Yes
17	Charles Gordon Sr. PS	all mechanical	3	13	No
17	David & Mary Tompson (new)	all mechanical	3	13	No
17	Donwood Park Jr. Public S.	no mechanical	3	13	Yes

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
17	Dorset Park Public School	no mechanical	3	17	Yes
17	East Education Office	all mechanical			No
17	Edgewood Public School	no mechanical	3	13	Yes
17	Ellesmere-Statton PS	partial mechanical	3	13	Yes
17	General Crerar Public School	no mechanical	3	17	Yes
17	George Peck Public School	no mechanical	3	18	Yes
17	Glamorgan Public School*	all mechanical	3	13	No
17	Glen Ravine Jr. Public School	no mechanical	3	13	Yes
17	Gooderham Learning Centre	no mechanical			Yes
17	Hunter's Glen Jr. Public S.	no mechanical	3	13	Yes
17	Ionview Public School	No Mechanical	3	17	Yes
17	John McCrae Public School	all mechanical	3	13	No
17	Knob Hill Public School	no mechanical	3	13	Yes
17	Lord Roberts Junior PS	no mechanical	3	13	Yes
17	Manhattan Park Junior PS	no mechanical	3	18	Yes
17	Maryvale Public School	partial mechanical	3	18	Yes
17	St Andrew's Jr PS/ASE	no mechanical	3	13/30	Yes
17	Terraview Heights/Parkview Alt/CSS LC2	all mechanical	3	18	No
17	Terraview-Willowfield PS	no mechanical	3	18	Yes
17	Wexford Collegiate School for the Arts	all mechanical	3	18	No
17	Wexford Public School	no mechanical	3	18	Yes
17	Winston Churchill CI	all mechanical	3	17	No
18	Anson Park Public School	no mechanical	3	17	Yes
18	Birch Cliff Heights PS	no mechanical	3	18	Yes
18	Birch Cliff Public School	no mechanical	3	18	Yes
18	Birchmount Park CI	all mechanical	3	18	No
18	Blantyre Public School	all mechanical	3	18	No
18	Bliss Carman Sr. Public School	all mechanical	3	16	No
18	Chine Drive Public School	no mechanical	3	17	Yes
18	Clairlea Public School	no mechanical	3	18	Yes
18	Cliffside JPS	no mechanical	3	18	Yes
18	Corvette Jr PS	no mechanical	3	17	Yes
18	Courcelette Public School	no mechanical	3	18	Yes
18	Danforth Gardens Public School	partial mechanical	3	18	Yes
18	Fairmount Public School	no mechanical	3	17	Yes
18	General Brock Public School	no mechanical	3	17	Yes
18	H A Halbert Jr PS	no mechanical	3	17	Yes
18	J.G. Workman Public School	no mechanical	3	3	Yes
18	John A. Leslie Public School	no mechanical	3	17	Yes
18	Mason Road Junior PS	partial mechanical	3	16	Yes
18	Norman Cook Junior PS	no mechanical	3	18	Yes
18	Oakridge Junior Public School	all mechanical	3	18	No
18	R.H. King Academy	partial mechanical	3	17	Yes
18	Regent Heights PS	no mechanical	3	18	Yes

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
18	Robert Service Senior PS	all mechanical	3	17	No
18	Samuel Hearne Middle School	all mechanical	3	18	No
18	SATEC @ W.A. Porter CI	partial mechanical	3	18	Yes
18	Scarborough Village PS*	all mechanical	3	17	No
18	SCAS/SEYRAC/CSS LC3	all mechanical	5	17/30/31	No
18	Taylor Creek PS	partial mechanical	3	18	Yes
18	Walter Perry Junior PS	no mechanical	3	17	Yes
19	Bellmere Junior Public School	all mechanical	3	13	No
19	Bendale Junior Public School	no mechanical	3	13	Yes
19	Cedar Drive Jr. Public School	all mechanical	3	16	No
19	Cedarbrae Collegiate Institute	all mechanical	3	15	No
19	Cedarbrook Public School	all mechanical	3	15	No
19	Churchill Heights PS	no mechanical	3	13	Yes
19	Cornell Jr. Public School	all mechanical	3	15	No
19	Eastview Public School	all mechanical	3	16	No
19	Elizabeth Simcoe Jr. PS	all mechanical	3	16	No
19	Galloway Road Public School	no mechanical	3	15	Yes
19	George B. Little Public School	no mechanical	3	13	Yes
19	George P Mackie Jr PS	no mechanical	3	16	Yes
19	Golf Road Jr PS	all mechanical	3	15	No
19	Guildwood Jr PS	no mechanical	3	16	Yes
19	Heather Heights JPS/Ben HeppnerVMAcademy	all mechanical	3	13	No
19	Henry Hudson Sr. Public School	all mechanical	3	13	No
19	Highcastle Public School	all mechanical	3	15	No
19	J.S. Woodsworth Senior PS	all mechanical	3	3	No
19	Jack Miner Sr. Public School	all mechanical	3	16	No
19	Maplewood High School*	all mechanical	3	16	No
19	Military Trail Public School	all mechanical	3	15	No
19	North Bendale Junior PS	partial mechanical	3	13	Yes
19	Poplar Road Junior PS	partial mechanical	3	16	Yes
19	Sir Wilfrid Laurier CI	all mechanical	3	16	No
19	St. Margaret's Public School	all mechanical	3	15	No
19	Tecumseh Senior Public School	all mechanical	3	15	No
19	Tredway Woodsworth Public School	partial mechanical	3	13	Yes
19	West Hill Collegiate Institute	all mechanical	3	15	No
19	Willow Park Junior PS	all mechanical	3	15	No
19	Woburn Collegiate Institute	all mechanical	3	13	No
19	Woburn Junior Public School	all mechanical	3	13	No
20	Agincourt Junior Public School	partial mechanical	2	10	Yes
20	Beverly Glen Jr. Public School	all mechanical	2	9	No
20	Bridlewood Jr. Public School	all mechanical	2	10	No
20	Brookmill Boulevard Jr PS	all mechanical	2	9	No
20	Chester Le Jr. Public School	all mechanical	2	9	No
20	David Lewis Public School	all mechanical	2	10	No

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
20	Dr. Norman Bethune CI	all mechanical	2	2	No
20	Fairglen Jr. Public School	all mechanical	2	10	No
20	Highland Heights Jr. PS	all mechanical	2	7	No
20	Inglewood Heights Jr PS	partial mechanical	2	10	Yes
20	J.B. Tyrrell Sr. Public School	all mechanical	2	2	No
20	John Buchan Senior PS	all mechanical	2	7	No
20	Kennedy Public School	all mechanical	2	10	No
20	L'Amoreaux CI	all mechanical	2	9	No
20	Lynngate Junior Public School	partial mechanical	2	10	Yes
20	Lynnwood Heights Junior PS	all mechanical	2	10	No
20	North Bridlewood Junior PS	partial mechanical	2	10	Yes
20	Pauline Johnson Junior PS	partial mechanical	2	7	Yes
20	Silver Springs Public School	all mechanical	2	9	No
20	Sir Ernest Macmillan Sr. PS	all mechanical	2	9	No
20	Sir John A. Macdonald CI	all mechanical	2	10	No
20	Sir Samuel B. Steele Jr. PS	all mechanical	2	10	No
20	Sir William Osler High School*	partial mechanical	2	10	Yes
20	Stephen Leacock CI	all mechanical	2	7	No
20	Tam O'Shanter Junior PS	all mechanical	2	7	No
20	Terry Fox Public School	all mechanical	2	10	No
20	Timberbank Junior PS	all mechanical	2	7	No
20	Vradenburg Junior PS	partial mechanical	2	10	Yes
21	Agincourt CI	partial mechanical	3	14	Yes
21	Agnes Macphail PS	all mechanical	3	14	No
21	Albert Campbell CI	all mechanical	3	17	No
21	Alexmuir Junior Public School	all mechanical	3	14	No
21	Anson S. Taylor Junior PS	all mechanical	3	17	No
21	Banting & Best Public School	all mechanical	3	14	No
21	Berner Trail Junior PS	all mechanical	3	14	No
21	Brimwood Boulevard Jr. PS	all mechanical	3	17	No
21	Brookside PS	all mechanical	3	14	No
21	Burrows Hall Jr. Public School	all mechanical	3	14	No
21	C D Farquharson Jr PS	no mechanical	3	14	Yes
21	Chartland Jr PS / Delphi Secondary Alt S	all mechanical	3	17	No
21	Dr Marion Hilliard Sr PS	all mechanical	3	14	No
21	Henry Kelsey Sr. Public School	all mechanical	3	17	No
21	Iroquois Jr PS	all mechanical	3	17	No
21	Lester B. Pearson CI	all mechanical	3	14	No
21	Macklin Public School	all mechanical	3	14	No
21	Malvern Junior Public School	all mechanical	3	14	No
21	Milliken Public School	all mechanical	3	14	No
21	North Agincourt Junior PS	No Mechanical	3	14	Yes
21	Percy Williams Junior PS	all mechanical	3	17	No
21	Port Royal PS	all mechanical	3	14	No

Ward	School Name	School Ventilation - see Notes below	LC	LN	HEPA Filters Provided
21	Sir Alexander Mackenzie Sr. PS	all mechanical	3	14	No
21	Tom Longboat Junior PS	all mechanical	3	14	No
21	White Haven Junior PS	all mechanical	3	14	No
22	Alexander Stirling PS	all mechanical	3	15	No
22	Alvin Curling Public School	all mechanical	3	15	No
22	Centennial Road Jr. PS	all mechanical	3	16	No
22	Charlottetown Jr. PS	all mechanical	3	16	No
22	Chief Dan George Public School	all mechanical	3	15	No
22	Emily Carr Public School	all mechanical	3	15	No
22	Fleming Public School	all mechanical	3	14	No
22	Grey Owl Public School	all mechanical	3	15	No
22	Heritage Park Public School	all mechanical	3	14	No
22	Highland Creek Public School	partial mechanical	3	15	Yes
22	Hillside Outdoor Education Ctr	all mechanical			No
22	John G. Diefenbaker PS	all mechanical	3	15	No
22	Joseph Brant PS	all mechanical	3	16	No
22	Joseph Howe Senior PS	all mechanical	3	16	No
22	Lucy Maud Montgomery PS	all mechanical	3	15	No
22	Mary Shadd Public School	all mechanical	3	14	No
22	Meadowvale Public School	partial mechanical	3	15	Yes
22	Morrish Public School	all mechanical	3	15	No
22	Rouge Valley Public School	all mechanical	3	16	No
22	Sir Oliver Mowat CI	all mechanical	3	16	No
22	Thomas L Wells Public School	all mechanical	3	14	No
22	West Hill Public School	all mechanical	3	15	No
22	West Rouge Junior PS	no mechanical	3	16	Yes
22	William G Davis Jr PS	partial mechanical	3	16	Yes
22	William G Miller Jr PS	all mechanical	3	16	No
	Highbrook Learning Centre	all mechanical			No
<b>Notes:</b>					
<b>All Mechanical</b> indicates that the school has a mechanical systems that provides both exhaust and supply air					
<b>No Mechanical</b> indicates a school that has exhaust but no supply air					
<b>Partial Mechanical</b> indicates a school that has some spaces in the school may have mechanical ventilation (some classrooms, FDK rooms, gymnasium, library, special education rooms or admin offices for example).					